

# HWU



## Henderson Water Utility

WATER • WASTEWATER • STORMWATER

 270.826.2421

 [www.hkywater.org](http://www.hkywater.org)

 111 Fifth Street  
Henderson, KY 42420

**Memo To:** Plan Holders

**From:** Tom Williams, P.E.  
HWU General Manager

**Re:** SWWTP Belt Press Rehab - Addendum No. 2  
Bid Reference: 2018-18

**Date:** 29 June 2018

In answer to questions submitted on the subject project:

1) **Question:** *What is the wage status of this job? Is it prevailing wage?*

**Answer:** Federal funds are being used to pay for a portion of the work, so payment of Davis Bacon wages is required. Certified payrolls shall be submitted to the Owner with each pay estimate after the first application.

2) **Question:** *Will the selected contractor provide the replacement parts, or will they be purchased by HWU?*

**Answer:** As specified on the Bid Form, Item 1, *“Vendor/Contractor proposes to furnish all equipment, accessories, and services for the renovation of belt filter press equipment (two presses) as specified herein.”*

3) **Question:** *The Scope of Work mentions removal of the presses and redelivery; may they be rebuilt in place?*

**Answer:** Rebuilding **in** place is allowed. However, the Vendor/Contractor shall visit the project site and determine the scope of services required to complete this work and priced scope shall include all services. This shall include removal and reinstallation of the equipment into the building if deemed necessary by the Vendor/Contractor.

4) **Question:** *The Scope of Work mentions no weekend work, only weekday without approval; will weekend work be approved?*

**Answer:** Weekend work is not preferred, but may be allowed, if prior approval is obtained. Any work that requires the presence of the Engineer’s Resident Observer shall not be performed on weekends.



Bid date/time remains the same; 1:30, Wednesday, 11 July 2018. If you have further questions, feel free to call me at 270.826.2421 (Office) or 270.823.2573 (Cell).

Cc: Stephen Lee, P.E., J.R. Wauford & Co.  
Kevin Roberts, HWU Director of Plant Operations  
Ken Ferry, P.E., HWU Chief Engineer