





**Henderson Water Utility**  
WATER • WASTEWATER • STORMWATER

 270.826.2421

 [www.hkywater.org](http://www.hkywater.org)

 111 Fifth Street  
Henderson, KY 42420

**Memo To:** Plan Holders

**From:** Tom Williams, P.E.  
HWU General Manager

**Re:** Addendum No. 1  
Painting Buildings at the Systems Operation Center  
Henderson Water Utility  
Bid Reference: 2018-33

**Date:** 23 July 2018

In answer to a question on the subject project:

1) *Question: Should rusted areas on the roof be primed?*

Answer: Yes. Prime rusted areas on the roof with Sherwin Williams 34-520 Uniflex Rust Inhibitive Metal Primer (or approved equal), at a rate of 250 square feet per gallon, dry film thickness 3.2 mils. The finish coat specified can be applied directly over this primer.

Bid date/time remains the same; 1:30, Wednesday, 25 July 2018. If you have further questions, feel free to call me at 270.826.2421 (Office) or 270.823.2573 (Cell).

