





Henderson Water Utility
WATER • WASTEWATER • STORMWATER

 270.826.2421

 www.hkywater.org

 111 Fifth Street
Henderson, KY 42420

June 12, 2019

RE: High Service Pump #3 Bid ADDENDUM #1

NEW BID OPENING DATE: Friday, June 14, 2019 at 1:30 p.m. local time

NOTE: In accordance with the bid document page 4 item 6b. “Telegraphic or facsimile offers shall not be considered unless authorized by the solicitation; however, offers may be modified by telegraphic or facsimile notice, if such notice is received prior to the hour and date specified for receipt. Telegraphic or facsimile modifications shall not mention unit prices or total price; but shall only refer to percentage change or numerical change (i.e., “reduce unit price of item 1 by \$1.00).”

So, if you have already sent a bid and these changes cause a change in your bid price you may either:

1. Send a new bid package with a note that it replaces any previously received bid package
2. Send a price/delivery adjustment according to the procedure outlined above.

Question: Is the line shaft maximum 60-inches in length equaling the column pipes or can the line shaft be 120-inches in length.

Answer: The line shaft must also be 60”

Question: What is the maximum operating speed?

Answer: Maximum operating speed is 1800 rpm.

Question: Should impeller material be a different material than bronze

Answer: Impeller material shall be nickel-aluminum-bronze, ASTM B-148, UNS C95-800 or latest update.

Kathy Ambrose, CPPO, CPPB
Purchasing Manager
Henderson Water Utility
270-869-6609
ambrosek@hkywater.org

