





Henderson Water Utility
WATER • WASTEWATER • STORMWATER

 270.826.2421

 www.hkywater.org

 111 Fifth Street
Henderson, KY 42420

June 13, 2019

RE: High Service Pump #3 Bid ADDENDUM #2

BID DATE: Friday, June 14, 2019 at 1:30 p.m. local time

NOTE: In accordance with the bid document page 4 item 6b. “Telegraphic or facsimile offers shall not be considered unless authorized by the solicitation; however, offers may be modified by telegraphic or facsimile notice, if such notice is received prior to the hour and date specified for receipt. Telegraphic or facsimile modifications shall not mention unit prices or total price; but shall only refer to percentage change or numerical change (i.e., “reduce unit price of item 1 by \$1.00).”

So, if you have already sent a bid and these changes cause a change in your bid price you may either:

1. Send a new bid package with a note that it replaces any previously received bid package
2. Send a price/delivery adjustment according to the procedure outlined above.

Question: Will this pump operate on a Variable Speed Drive

Answer: No

Question: Will you accept a Cast Iron discharge head?

Answer: yes

Question: Does the pump need to be a bolt-in application or are piping modifications acceptable

Answer: Piping modifications are acceptable

Kathy Ambrose, CPPO, CPPB
Purchasing Manager
Henderson Water Utility
270-869-6609
ambrosek@hkywater.org

