





Henderson Water Utility
WATER • WASTEWATER • STORMWATER

 270.826.2421

 www.hkywater.org

 111 Fifth Street
Henderson, KY 42420

June 10, 2019

RE: High Service Pump #3 Bid Clarification #1

General: The pump will be used with Potable Water
The pump will need to be NSF 61 Certified

Question: Would you consider a pump with an NSF 61 certified coating like the Tnemex Pota Pox Series 20? All pump and pipe components would have this coating inside and outside.

Answer: Yes

Question: May we submit a Boesch Vertical Turbine Pump as an “equal” for the solicitation?

Answer: Yes

Kathy Ambrose, CPPO, CPPB
Purchasing Manager
Henderson Water Utility
270-869-6609
ambrosek@hkywater.org

