



**Henderson Water Utility**  
WATER • WASTEWATER • STORMWATER

📞 270.826.2421

💻 [www.hkywater.org](http://www.hkywater.org)

📍 111 Fifth Street  
Henderson, KY 42420

**Memo To:** Plan Holders

**From:** Tom Williams, P.E.  
HWU General Manager

**Re:** Generator Project - Addendum No. 3  
Bid Reference: 2020 - 04

**Date:** 11 September 2020

Questions from Bidders, and Answers, so far:

1. Question: At the Admin Building, Sheet E-1, drawing shows connecting to 2, 200-amp disconnects, for 2 panels in the building, but the ATS is 200 amp. Doesn't it need to be 400 amp?

Answer: It does need to be 400A with a 4/0 AWG service to each disconnect.

2. Question: How will the Bid Opening be made public, when Kentucky is still under modified lock-down procedures?

Answer: Bidders should submit their sealed bids by customary means, prior to the bid opening time. At the specified time, a video teleconference will be broadcast to the public as allowed under KRS 61.826 and KRS 45A.080(4).

No primary location will be set for public attendance as per Kentucky Attorney General Opinion 20-05, and no public attendance will be permitted at this meeting due to the highly contagious nature of COVID-19.

**The Bid Opening will be broadcast on Zoom:**

When: 16 September 2020, 01:30 PM Central Time (US and Canada)

Register in advance for this meeting:

<https://zoom.us/meeting/register/tJlc-ygrDwiGtyATj0KVbetDk7dbEPofQP>

After registering, you will receive a confirmation email containing information about joining the meeting.

Bid opening date/time remains the same: 1:30 p.m., 16 September 2020, online, as noted above.



If you have further questions, feel free to call me at 270.826.2421 (Office).

We have extended the last day for questions to noon, Tuesday, 15 September 2020, and will issue a final addendum after that if necessary.

Cc: Bart Boles, HWU Project Engineer  
Kathy Manker, HWU Procurement Manager