

Memo To: Plan Holders

From: Tom Williams, P.E.
HWU General Manager

Re: Sellars Ditch Water Crossing Project - Addendum No. 1
Bid Reference: 2019 - 19

Date: 27 August 2019

Questions and Answers from Bidders, so far:

1. Question: Does the HDPE need to be upsized to 14" to get the same ID as the 12" Fusible PVC?
Answer: The Fusible PVC pipe furnished should be 10". Revised bid form is attached reflecting this change on Item 3.

Bid opening date remains the same: 1:30 p.m., 4 September 2019, at the office address listed above.

If you have further questions, feel free to call me at 270.826.2421 (Office).

Cc: Ken Ferry, P.E., HWU Chief Engineer



TOTAL BASE BID PRICE (Item 1 & 2)

TOTAL BID PRICE _____

_____ Dollars (\$ _____).
(Use words) (figures)

Bidders – please attach a “post-it” note or other tag to this page, in your completed bid.

ALTERNATE BID ITEM No. 3: 10” Fusible PVC Water Main – Directional Drilling

655 Linear Feet of 10” Fusible PVC Water Pipe, including furnishing and installing all pipe, connections, joint materials and other materials required for installation; fusion welding; installation by directional drilling; flanged end connections on each end of the bored pipe; hydrostatic testing; all complete in place and ready for use.

655 Linear Feet @ \$ _____ Equals \$ _____
Unit Price L.F. Extended Amount

It is the Owner’s intention to award this bid to the lower of the Primary or Alternate Bid Prices (either Bid Item 2 OR Bid Item 3).

**Bidders are not required to submit pricing on both items.
If not submitting a Bid on an item, write “N/A” in both blank spaces for that item.**