

**Effective 07/01/2014**

<b>Effluent Discharge Limitations</b>	
Henderson North Wastewater Treatment Plant City of Henderson, Kentucky	
<b>Parameter</b>	<b>Daily Maximum Discharge Limit (milligrams per liter)</b>
Arsenic (As)	0.34
Cadmium (Cd)	0.06
Chromium, total (Cr)	2.77
Hexavalent Chromium (Cr VI)	0.53
Copper (Cu)	1.43
Cyanide, Amenable (Cn, Amen)	0.26
Lead (Pb)	0.24
Mercury (Hg)	0.01
Nickel (Ni)	1.64
Selenium (Se)	0.14
Silver (Ag)	0.39
Zinc (Zn)	1.60

<b>Effluent Discharge Limitations</b>	
Henderson South Wastewater Treatment Plant City of Henderson, Kentucky	
<b>Parameter</b>	<b>Daily Maximum Discharge Limit (milligrams per liter)</b>
Arsenic (As)	0.17
Cadmium (Cd)	0.11
Chromium, total (Cr)	2.77
Hexavalent Chromium (Cr VI)	1.55
Copper (Cu)	2.03
Cyanide, Amenable (Cn, Amen)	0.65
Lead (Pb)	0.69
Mercury (Hg)	0.004
Nickel (Ni)	1.57
Selenium (Se)	0.38
Silver (Ag)	0.24
Zinc (Zn)	1.48