





Henderson Water Utility
WATER • WASTEWATER • STORMWATER

 270.826.2421

 www.hkywater.org

 111 Fifth Street
Henderson, KY 42420

Memo To: Plan Holders

From: Tom Williams, P.E.
HWU General Manager

Re: AMI Equipment Installation – Phase A - Addendum No. 1
Bid Reference: 2021 - 02

Date: 15 February 2021

Questions from Bidders, and Answers, so far:

1. Question: ITEM No. 6: Repeater 100 Installation – 2929 Marlow Court (Site R-25) - Installation of a Repeater 100 on contractor-furnished and installed 45' wood pole at 2929 Marlow Court

Is this a 45' overall pole length before installation, or 45' overall Above Ground Level Height pole after installation?

Answer: This is meant to be 45' above ground, so that the repeater is at or near 45' above grade.

2. Question: How will the Bid Opening be made public, when Kentucky is still under modified lock-down procedures?

Answer: Bidders should submit their sealed bids by customary means, prior to the bid opening time. At the specified time, a video teleconference will be broadcast to the public as allowed under KRS 61.826 and KRS 45A.080(4).

No primary location will be set for public attendance as per Kentucky Attorney General Opinion 20-05, and no public attendance will be permitted at this meeting due to the highly contagious nature of COVID-19.

The Bid Opening will be broadcast on Zoom:

When: 18 February 2021, 01:30 PM Central Time (US and Canada)

Register in advance for this meeting:

<https://zoom.us/meeting/register/tJclc-ygrDwiGtyATjJ0KVbetDk7dbEPofQP>

After registering, you will receive a confirmation email containing information about joining the meeting.

Bid opening date/time remains the same: 1:30 p.m., 18 February 2021, online, as noted above.

If you have further questions, feel free to call me at 270.826.2421 (Office).

Cc: Bart Boles, HWU Project Engineer
Warner Mattingly, HWU Project Engineer
Kathy Manker, HWU Procurement Manager